

| | |
|---------------------------------|------------------------------------|
| SINGAPORE/PAYALEBAR SR | |
| Latitude = 1.37 N | WMO No. 486940 |
| Longitude = 103.92 E | Elevation = 105 Feet |
| Period of Record = 1949 TO 1983 | Average Pressure = 29.72 inches Hg |


Design Criteria Data

| | | Mean Coincident (Average) Values | | | |
|--|--------------|----------------------------------|----------------|------------------------|------------------------|
| | Design Value | Wet Bulb Temperature | Humidity Ratio | Wind Speed | Prevailing Direction |
| | (°F) | (°F) | (gr/lb) | (mph) | (NSEW) |
| Dry Bulb Temperature (T) | | | | | |
| Median of Extreme Highs | 92 | 79 | 126 | 8.1 | E |
| 0.4% Occurrence | 91 | 79 | 129 | 7.6 | S |
| 1.0% Occurrence | 90 | 78 | 129 | 7.6 | S |
| 2.0% Occurrence | 90 | 78 | 129 | 7.6 | S |
| Mean Daily Range | 9 | - | - | - | - |
| 97.5% Occurrence | 73 | 72 | 118 | 4.4 | MISSING |
| 99.0% Occurrence | 73 | 72 | 118 | 4.4 | MISSING |
| 99.6% Occurrence | 72 | 72 | 116 | 4.4 | MISSING |
| Median of Extreme Lows | 70 | 70 | 107 | 5.7 | MISSING |
| | | Mean Coincident (Average) Values | | | |
| | Design Value | Dry Bulb Temperature | Humidity Ratio | Wind Speed | Prevailing Direction |
| | (°F) | (°F) | (gr/lb) | (mph) | (NSEW) |
| Wet Bulb Temperature (T_{wb}) | | | | | |
| Median of Extreme Highs | 83 | 88 | 155 | 6.2 | ESE |
| 0.4% Occurrence | 81 | 87 | 146 | 5.8 | S |
| 1.0% Occurrence | 80 | 86 | 142 | 5.7 | S |
| 2.0% Occurrence | 80 | 86 | 142 | 5.7 | S |
| | | Mean Coincident (Average) Values | | | |
| | Design Value | Dry Bulb Temperature | Vapor Pressure | Wind Speed | Prevailing Direction |
| | (gr/lb) | (°F) | (in. Hg) | (mph) | (NSEW) |
| Humidity Ratio (HR) | | | | | |
| Median of Extreme Highs | 162 | 86 | 1.07 | 7.4 | MISSING |
| 0.4% Occurrence | 151 | 83 | 0.99 | 4.0 | MISSING |
| 1.0% Occurrence | 151 | 83 | 0.99 | 3.9 | MISSING |
| 2.0% Occurrence | 151 | 83 | 0.99 | 3.9 | MISSING |
| Air Conditioning/ Humid Area Criteria | # of Hours | T ≥ 93°F | T ≥ 80°F | T _{wb} ≥ 73°F | T _{wb} ≥ 67°F |
| | | 8 | 3949 | 8271 | 8608 |


Other Site Data

| Weather Region | Rain Rate 100 Year Recurrence (in./hr) | Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph) | Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible |
|--|--|--|---|
| 10 | N/A | N/A | 11.5 + 4.2 |
| Ground Water Temperature (°F) 50 Foot Depth * | Frost Depth 50 Year Recurrence (in.) | Ground Snow Load 50 Year Recurrence (lb/ft ²) | Average Annual Freeze-Thaw Cycles (#) |
| 82.4 | N/A | N/A | 0 |


*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.



Long Term Psychrometric Summary



- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations



| | (°F) | MCHR (gr/lb) | Enthalpy (btu/lb) | 1.0% Humidity Ratio | (gr/lb) | MCDB (°F) | MCWB (°F) | MC Dewpt (°F) | Enthalpy (btu/lb) |
|---------------------|------|-----------------|----------------------|--------------------------------|---------|--------------|--------------|------------------|----------------------|
| 99% Dry Bulb | 73 | 116.6 | 35.7 | | 150.5 | 82.9 | 79.9 | 78.8 | 43.5 |

| | (°F) | MCHR (gr/lb) | MCWB (°F) | Enthalpy (btu/lb) |
|----------------------|------|-----------------|--------------|----------------------|
| 1.0% Dry Bulb | 90 | 129.8 | 78.6 | 42.0 |

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1949 TO 1983

| Temperature Range (°F) | January | | | | | February | | | | | March | | | | |
|------------------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|
| | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) |
| | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | |
| 100 / 104 | | | | | | | | | | | | | | | |
| 95 / 99 | | | | | | | | | | | | 1 | 0 | 1 | 78.4 |
| 90 / 94 | | 2 | 0 | 2 | 76.7 | 0 | 12 | 1 | 13 | 77.5 | | 28 | 4 | 32 | 78.1 |
| 85 / 89 | | 63 | 6 | 69 | 76.5 | 0 | 80 | 11 | 91 | 76.8 | 0 | 103 | 16 | 119 | 77.8 |
| 80 / 84 | 0 | 128 | 50 | 178 | 75.6 | 1 | 95 | 69 | 165 | 76.2 | 3 | 89 | 98 | 190 | 76.9 |
| 75 / 79 | 142 | 49 | 171 | 361 | 74.3 | 165 | 35 | 134 | 334 | 74.8 | 211 | 25 | 125 | 361 | 75.4 |
| 70 / 74 | 106 | 6 | 21 | 133 | 71.9 | 58 | 2 | 9 | 69 | 72.2 | 34 | 2 | 5 | 41 | 72.5 |
| 65 / 69 | 0 | | | 0 | 67.0 | 0 | | 0 | 0 | 67.5 | | | | | |

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1949 TO 1983

| Temperature Range (°F) | April | | | | | May | | | | | June | | | | |
|------------------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|
| | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) |
| | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | |
| 100 / 104 | | | | | | | | | | | | | | | |
| 95 / 99 | | 0 | | 0 | 78.8 | | 0 | 0 | 0 | 79.8 | | 0 | | 0 | 79.8 |
| 90 / 94 | | 31 | 4 | 35 | 79.0 | 0 | 34 | 3 | 37 | 79.4 | | 23 | 2 | 25 | 79.1 |
| 85 / 89 | 0 | 104 | 16 | 120 | 78.7 | 0 | 116 | 20 | 136 | 79.1 | 0 | 115 | 23 | 139 | 78.7 |
| 80 / 84 | 11 | 77 | 115 | 203 | 77.9 | 36 | 76 | 142 | 253 | 78.2 | 43 | 74 | 138 | 255 | 77.9 |
| 75 / 79 | 219 | 26 | 104 | 349 | 76.1 | 206 | 21 | 81 | 308 | 76.4 | 183 | 24 | 75 | 282 | 76.1 |
| 70 / 74 | 10 | 1 | 2 | 13 | 72.7 | 6 | 2 | 2 | 10 | 72.7 | 14 | 3 | 2 | 19 | 72.6 |
| 65 / 69 | | | | | | 0 | | | 0 | 68.0 | | | | | |

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1949 TO 1983

| Temperature Range (°F) | July | | | | | August | | | | | September | | | | |
|------------------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|
| | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) |
| | To 01 08 | To 09 16 | To 17 00 | | | To 01 08 | To 09 16 | To 17 00 | | | To 01 08 | To 09 16 | To 17 00 | | |
| 100 / 104 | | | | | | | | | | | | | | | |
| 95 / 99 | | | 0 | 0 | 78.0 | | | 0 | | 81.0 | | | | | |
| 90 / 94 | 0 | 13 | 1 | 14 | 78.5 | 0 | 7 | 1 | 8 | 78.3 | | 6 | 0 | 6 | 78.4 |
| 85 / 89 | 0 | 103 | 18 | 121 | 78.1 | 0 | 107 | 17 | 124 | 78.0 | 0 | 101 | 13 | 114 | 77.8 |
| 80 / 84 | 41 | 99 | 138 | 277 | 77.4 | 31 | 99 | 140 | 270 | 77.3 | 14 | 99 | 122 | 234 | 77.2 |
| 75 / 79 | 178 | 30 | 87 | 295 | 75.7 | 189 | 32 | 85 | 306 | 75.7 | 198 | 32 | 101 | 331 | 75.7 |
| 70 / 74 | 29 | 4 | 4 | 37 | 72.6 | 28 | 4 | 5 | 37 | 72.6 | 28 | 3 | 4 | 35 | 72.6 |
| 65 / 69 | | | | | | | | | | | | 0 | | 0 | |

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1949 TO 1983

| Temperature Range (°F) | October | | | | | November | | | | | December | | | | | | |
|------------------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|------------------|----------|----------|-----------|--------------|--|--|
| | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) | | |
| | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | | 01 To 08 | 09 To 16 | 17 To 00 | | | | |
| 100 / 104 | | 0 | | 0 | 83.0 | | | | 0 | 0 | 82.0 | | | | | | |
| 95 / 99 | | 0 | | 0 | 80.0 | | | | 0 | 0 | 82.0 | | | | | | |
| 90 / 94 | | 17 | 1 | 18 | 77.9 | 0 | 4 | 0 | 4 | 78.4 | | 0 | 0 | 0 | 78.4 | | |
| 85 / 89 | 0 | 104 | 11 | 115 | 77.8 | 0 | 74 | 6 | 80 | 77.8 | 0 | 54 | 2 | 56 | 77.4 | | |
| 80 / 84 | 7 | 94 | 105 | 206 | 77.3 | 2 | 112 | 59 | 173 | 77.2 | 0 | 130 | 43 | 173 | 76.7 | | |
| 75 / 79 | 215 | 31 | 128 | 374 | 75.7 | 197 | 46 | 165 | 408 | 75.4 | 176 | 58 | 186 | 419 | 74.9 | | |
| 70 / 74 | 26 | 2 | 3 | 31 | 72.7 | 41 | 4 | 10 | 55 | 72.7 | 72 | 6 | 17 | 95 | 72.5 | | |
| 65 / 69 | | | | | | | | | | | | | | | | | |

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SINGAPORE/PAYALEBAR SR


WMO No. 486940


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1949 TO 1983

| Annual Totals | | | | | |
|------------------------|------------------|----------|----------|-----------|--------------|
| Temperature Range (°F) | Hour Group (LST) | | | Total Obs | M C W B (°F) |
| | 01 To 08 | 09 To 16 | 17 To 00 | | |
| 100 / 104 | | 0 | | 0 | 83.0 |
| 95 / 99 | | 2 | 0 | 2 | 79.3 |
| 90 / 94 | 1 | 180 | 20 | 201 | 78.6 |
| 85 / 89 | 3 | 1125 | 160 | 1288 | 78.0 |
| 80 / 84 | 188 | 1169 | 1217 | 2574 | 77.2 |
| 75 / 79 | 2276 | 406 | 1441 | 4123 | 75.5 |
| 70 / 74 | 452 | 39 | 82 | 573 | 72.4 |
| 65 / 69 | 0 | 0 | 0 | 0 | 67.5 |

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.






SINGAPORE/PAYALEBAR SR


WMO No. 486940

Long Term Dry Bulb Temperature and Humidity Summary

| Week Ending | 1.0% Temp (°F) | MCWB @ 1% Temp (°F) | Mean Max Temp (°F) | Mean Min Temp (°F) | 99% Temp (°F) | 1.0% HR (gr/lb) | MCDB @ 1% HR (°F) | Mean Max HR (gr/lb) | Mean Min HR (gr/lb) |
|-------------|----------------|---------------------|--------------------|--------------------|---------------|-----------------|-------------------|---------------------|---------------------|
| 7-Jan | 88.0 | 77.1 | 83.2 | 74.6 | 72.0 | 141.4 | 80.4 | 132.2 | 119.8 |
| 14-Jan | 88.0 | 77.7 | 83.0 | 74.2 | 72.0 | 141.4 | 81.9 | 128.2 | 117.5 |
| 21-Jan | 88.0 | 76.9 | 83.6 | 74.4 | 72.0 | 141.4 | 81.1 | 128.2 | 116.2 |
| 28-Jan | 88.0 | 76.4 | 84.5 | 74.6 | 72.0 | 141.4 | 81.8 | 127.3 | 115.4 |
| 4-Feb | 90.0 | 77.3 | 84.9 | 74.6 | 72.0 | 141.4 | 81.8 | 130.0 | 117.2 |
| 11-Feb | 90.0 | 77.0 | 85.0 | 74.9 | 72.0 | 141.4 | 81.5 | 130.7 | 117.6 |
| 18-Feb | 90.0 | 77.7 | 85.7 | 75.4 | 73.0 | 142.1 | 80.7 | 132.4 | 120.1 |
| 25-Feb | 90.0 | 77.7 | 85.4 | 75.0 | 73.0 | 142.1 | 81.3 | 132.5 | 118.6 |
| 4-Mar | 91.0 | 77.2 | 85.8 | 75.1 | 73.0 | 142.1 | 81.7 | 133.6 | 119.8 |
| 11-Mar | 91.0 | 77.4 | 86.4 | 75.5 | 73.0 | 142.1 | 81.1 | 134.9 | 121.4 |
| 18-Mar | 91.0 | 78.5 | 86.5 | 75.8 | 73.0 | 142.1 | 81.8 | 134.8 | 121.9 |
| 25-Mar | 90.0 | 78.3 | 87.1 | 76.0 | 73.0 | 146.3 | 87.6 | 137.6 | 122.6 |
| 1-Apr | 91.0 | 78.1 | 86.6 | 76.4 | 73.0 | 150.5 | 83.9 | 139.6 | 124.8 |
| 8-Apr | 91.0 | 79.6 | 86.3 | 76.5 | 73.0 | 151.2 | 82.5 | 141.0 | 126.9 |
| 15-Apr | 91.0 | 79.5 | 86.5 | 76.7 | 74.0 | 150.5 | 84.0 | 141.6 | 126.9 |
| 22-Apr | 91.0 | 78.5 | 87.0 | 76.7 | 73.0 | 151.2 | 83.0 | 143.4 | 126.7 |
| 29-Apr | 91.0 | 78.8 | 87.0 | 77.0 | 73.0 | 151.2 | 82.8 | 143.2 | 127.3 |
| 6-May | 91.0 | 79.1 | 86.7 | 76.9 | 74.0 | 151.2 | 82.2 | 144.1 | 127.7 |
| 13-May | 91.0 | 79.7 | 86.8 | 76.9 | 73.0 | 159.6 | 85.3 | 145.2 | 128.7 |
| 20-May | 91.0 | 79.2 | 86.8 | 77.5 | 75.0 | 159.6 | 82.3 | 145.4 | 129.1 |
| 27-May | 91.0 | 79.7 | 87.0 | 77.7 | 73.0 | 151.2 | 83.1 | 144.7 | 128.0 |
| 3-Jun | 91.0 | 79.2 | 86.8 | 77.6 | 75.0 | 151.2 | 83.2 | 145.0 | 128.3 |
| 10-Jun | 90.0 | 79.0 | 87.0 | 77.7 | 74.0 | 151.2 | 83.0 | 143.6 | 128.4 |
| 17-Jun | 90.0 | 79.0 | 86.1 | 77.4 | 73.0 | 151.2 | 82.8 | 142.5 | 126.8 |
| 24-Jun | 90.0 | 79.2 | 86.2 | 77.0 | 73.0 | 150.5 | 83.0 | 141.4 | 124.7 |
| 1-Jul | 90.0 | 79.5 | 85.7 | 77.0 | 73.0 | 150.5 | 83.1 | 140.8 | 125.0 |
| 8-Jul | 90.0 | 78.0 | 86.3 | 76.9 | 73.0 | 150.5 | 82.1 | 140.6 | 123.6 |
| 15-Jul | 90.0 | 78.5 | 85.6 | 76.5 | 73.0 | 150.5 | 82.3 | 138.5 | 122.8 |
| 22-Jul | 90.0 | 79.1 | 85.0 | 76.7 | 73.0 | 150.5 | 83.2 | 138.3 | 124.7 |
| 29-Jul | 88.0 | 78.7 | 84.8 | 76.6 | 73.0 | 150.5 | 82.8 | 138.8 | 123.5 |
| 5-Aug | 90.0 | 78.0 | 85.9 | 76.8 | 73.0 | 150.5 | 82.3 | 138.6 | 123.0 |
| 12-Aug | 89.0 | 78.3 | 85.4 | 76.8 | 73.0 | 150.5 | 82.0 | 137.9 | 123.3 |
| 19-Aug | 89.0 | 79.3 | 85.4 | 76.9 | 73.0 | 150.5 | 82.8 | 138.9 | 124.3 |
| 26-Aug | 89.0 | 77.9 | 85.4 | 76.5 | 73.0 | 150.5 | 83.1 | 138.5 | 123.5 |
| 2-Sep | 88.0 | 77.8 | 84.9 | 75.8 | 73.0 | 150.5 | 82.8 | 138.3 | 122.4 |
| 9-Sep | 88.0 | 77.8 | 85.0 | 76.1 | 73.0 | 146.3 | 82.9 | 137.6 | 123.0 |
| 16-Sep | 89.0 | 77.9 | 85.5 | 76.0 | 73.0 | 150.5 | 82.7 | 138.6 | 122.3 |
| 23-Sep | 89.0 | 77.9 | 85.8 | 76.4 | 73.0 | 150.5 | 82.1 | 138.5 | 123.6 |
| 30-Sep | 90.0 | 78.2 | 85.5 | 76.3 | 73.0 | 150.5 | 81.9 | 138.6 | 122.2 |
| 7-Oct | 90.0 | 78.2 | 86.3 | 76.2 | 73.0 | 147.0 | 83.3 | 138.1 | 122.3 |
| 14-Oct | 90.0 | 77.7 | 85.5 | 76.0 | 73.0 | 147.0 | 79.9 | 138.1 | 122.0 |
| 21-Oct | 90.0 | 78.0 | 85.5 | 75.8 | 73.0 | 147.0 | 82.0 | 138.2 | 123.6 |
| 28-Oct | 90.0 | 78.0 | 85.5 | 75.8 | 73.0 | 147.0 | 84.8 | 138.2 | 123.2 |
| 4-Nov | 88.0 | 78.5 | 85.3 | 75.6 | 73.0 | 142.1 | 80.9 | 137.7 | 123.5 |
| 11-Nov | 90.0 | 78.8 | 85.1 | 75.3 | 73.0 | 142.1 | 80.8 | 137.4 | 122.7 |
| 18-Nov | 89.0 | 78.1 | 84.7 | 75.4 | 73.0 | 150.5 | 84.1 | 137.7 | 123.1 |
| 25-Nov | 88.0 | 78.1 | 84.4 | 75.3 | 73.0 | 142.1 | 81.0 | 136.7 | 123.7 |
| 2-Dec | 88.0 | 77.5 | 83.5 | 75.0 | 73.0 | 142.1 | 81.3 | 135.4 | 123.1 |
| 9-Dec | 88.0 | 77.5 | 84.0 | 74.7 | 72.0 | 142.1 | 80.8 | 134.7 | 122.2 |
| 16-Dec | 88.0 | 77.7 | 83.8 | 74.8 | 73.0 | 142.1 | 80.7 | 134.2 | 121.9 |
| 23-Dec | 88.0 | 77.4 | 83.3 | 74.8 | 72.0 | 141.4 | 81.0 | 133.0 | 121.1 |
| 31-Dec | 88.0 | 78.1 | 83.2 | 74.7 | 72.0 | 141.4 | 80.9 | 132.1 | 120.7 |





| | Mean Cooling Degree Days (°F) | Mean Heating Degree Days (°F) |
|-----|-------------------------------|-------------------------------|
| JAN | 304 | 0 |
| FEB | 304 | 0 |
| MAR | 365 | 0 |
| APR | 366 | 0 |
| MAY | 390 | 0 |
| JUN | 379 | 0 |
| JUL | 373 | 0 |
| AUG | 360 | 0 |
| SEP | 337 | 0 |
| OCT | 340 | 0 |
| NOV | 302 | 0 |
| DEC | 295 | 0 |
| ANN | 4113 | 0 |





| | Average Sensible Cooling Load (Btu/cfm) | Average Sensible Heating Load (Btu/cfm) | Average Latent Cooling Load (Btu/cfm) | Average Latent Heating Load (Btu/cfm) |
|-----|---|---|---------------------------------------|---------------------------------------|
| JAN | 3014 | 0 | 9793 | 0 |
| FEB | 3302 | 0 | 9890 | 0 |
| MAR | 4510 | 0 | 12090 | 0 |
| APR | 4784 | 0 | 12836 | 0 |
| MAY | 5276 | 0 | 13659 | 0 |
| JUN | 5091 | 0 | 12335 | 0 |
| JUL | 4693 | 0 | 11609 | 0 |
| AUG | 4490 | 0 | 11519 | 0 |
| SEP | 4258 | 0 | 10977 | 0 |
| OCT | 4232 | 0 | 11314 | 0 |
| NOV | 3435 | 0 | 10990 | 0 |
| DEC | 3014 | 0 | 10741 | 0 |
| ANN | 50099 | 0 | 137753 | 0 |

Wind Summary - December, January, and February
Labels of Percent Frequency on North Axis




Percent Calm = .

Wind Summary - March, April, and May
Labels of Percent Frequency on North Axis




Percent Calm = .

Wind Summary - June, July, and August
Labels of Percent Frequency on North Axis



Percent Calm = .

Wind Summary - September, October, and November
Labels of Percent Frequency on North Axis



Percent Calm = .